

SECTION

16.0.0 Stair and Elevator Shaft Construction

The stairs and elevator shafts of all buildings more than one story in height, except private dwellings, shall be enclosed continuously by incombustible material having a fire resistance rating of not less than two hours. In nonfire-resistive buildings such stair and elevator shafts shall be supported directly on foundations, and shall be constructed of masonry or concrete.