

## **SECTION**

### **26.0.0 Fire Resistance and Fire Protection**

#### **26.1.0 Fire Resistance Ratings in Construction**

Repealed, Ord. #1264, 6/15/98

#### **26.2.0 Fire Protection in Building Construction**

Repealed, Ord. #1264, 6/15/98

##### **26.2.1 Sprinklers Required**

Repealed, Ord. #1264, 6/15/98

##### **26.2.2 Fire Protection Equipment Plan Submittal**

Repealed, Ord. #1264, 6/15/98

##### **26.2.3 Sprinkler System Alarms**

Repealed, Ord. #1264, 6/15/98

#### **26.3.0 Fire Alarm System**

Repealed, Ord. #1264, 6/15/98

##### **26.3.1 Fire Alarm Systems Required**

Repealed, Ord. #1264, 6/15/98

##### **26.3.2 Automatic Detection**

Repealed, Ord. #1264, 6/15/98

##### **26.3.3 Design**

Repealed, Ord. #1264, 6/15/98

##### **26.4.1 Standpipes and Hose Systems**

Repealed, Ord. #1264, 6/15/98

#### **26.5.0 Fire Hydrant Spacing (Ord. 774, 4/15/85)**

Single Family Residential - Fire hydrant spacing shall be installed at intervals not to exceed 300 feet unless a greater distance is approved by the Fire Chief, in writing, after due consideration of existing water supply and pressure in the area, additional expense to the owner as compared to the enhancement of fire fighting capability, and such other factors as are reasonably deemed relevant by the Fire Chief. In no event shall the Fire Chief approve hydrant intervals which are greater than 400 feet.

Other Than Single Family Residential - Fire hydrants shall be installed such that no portion of the principal building or group of buildings is located more than 250 feet from the nearest fire hydrant unless a greater distance is approved, in writing, by the Fire Chief after due consideration of existing water supply and pressure to the site, the use to which the site will be put, the additional expense to the developer as compared to the enhancement of fire fighting capability, and such other factors as are reasonably deemed relevant by the Fire Chief. In no event shall the Fire Chief approve a distance which is greater than 300 feet.