

SECTION**27.0.0 Roof Coverings****27.1.0 Roof Slopes**

Exterior sloping surfaces of buildings which rise forty-eight inches (48") or less in twelve inches of run (48:12) are hereby defined to be roof surfaces and shall comply with the requirements of this Section. Roof surfaces shall be covered with standard roofing material recommended by the manufacturer for the particular slope and conditions of the roof in each case.

27.2.0 Roof Covering Materials

Roof surfaces shall be covered with one of the following materials:

- A. Built-up 3-ply felt and coal tar pitch or asphalt roofing with gravel or slag surfacing, limited to a maximum slope of one inch in twelve inches (1:12).
- B. Built-up 3-ply asbestos felt and asphalt smooth surfaced roofing, limited to a minimum slope of one-half inch in twelve inches (1/2:12).
- C. Metal roofing.
- D. Poured concrete or precast concrete panels or tiles.
- E. Slate shingles or other natural stone units.
- F. Hard burned clay roofing tiles.
- G. Cement asbestos shingles 5/32 inch thick.
- H. Asphalt shingles - U.S. Class "C" or better.
- I. Wood shingles chemically fire treated and bearing Underwriters' Class "C" label. **(Ord. 640, 1/16/78)**