

SECTION**31.0.0 Storage Tanks****31.1.0 References: By Adoption**

Unless otherwise stated in this ordinance, the provisions of Hazardous Use Units of "The National Building Code" of the American Insurance Association, current edition, abbreviated, and "Fire Resistance Ratings" of the American Insurance Association, successors to the National Board of Fire Underwriters, Engineering and Safety Department, 85 John Street, New York, New York 10038, copies of which are on file with the Village Clerk, are hereby adopted by reference in this ordinance whenever it applies or refers to tanks containing volatile, flammable, corrosive or hazardous liquids, fluids or gasses.

31.2.0 Foundations

Foundations for all types of tanks will conform to the foundation requirements listed under Section 20.0.0 entitled "Concrete Construction" and Section 19.0.0 entitled "Footings, Foundations and Slabs" of this ordinance and with all the structural requirements of this ordinance unless otherwise stated.

31.3.0 Permits and Fees (Ord. 688, 8/18/80)

Building permit shall be required for the installation of tanks for flammable, volatile, or corrosive, or hazardous liquids, fluids, or gasses, or large water or other non-flammable liquid tanks, unless installed as a part of a building or structure covered by a Building Permit. The application shall include a sketch or drawing showing the location of each tank and details of the installation along with specifications of the tank including the manufacturers date and inspection agency labels. A specific fee for each tank of 5,000 gallon capacity or less will be charged. Another fee for each tank of over 5,000 gallon capacity will be charged for such separate Building Permits. These fees are as stated in Chapter 25, Section 25.205 of the Flossmoor Municipal Code. **(FMC-307, 7/17/95)**